



Product certificate K76981/01

Issued 2013-03-19

Replaces

Page 1 of 3

Gate valves

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the products supplied by


Fucoli - Somepal fundição de ferro, S.A.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline

Kiwa evaluation guideline BRL-K602: "Valves and other accessories for drinking water transport and drinking water distribution systems",

which covers the requirements of

EN 1074-2: 2000: "Valves for water supply – Fitness for purpose requirements and appropriate verification tests – Part 2: Isolating valves".



Bouke Meekma
Kiwa

Publication of the certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.
Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands

Tel. +31 70 414 44 00
Fax +31 70 414 44 20
info@kiwa.nl
www.kiwa.nl



Supplier

Fucoli - Somepal fundição de ferro, S.A.
Apartado 4 - Rua de Aveiro, 50
3050-903 PAMPILHOSA
Portugal
Tel. +351 239 490100
Fax +351 239 490198 / 490199
e-mail: sede@fucoli-somepal.pt
www.fucoli-somepal.pt

Certification process
consists of initial and
regular inspection of:

- quality system
- product

Gate valves

Product specification

The products mentioned below belong to this certificate

Series : 3000 S14 double flanged (short model)

Series 3000 S15 double flanged (long model)

Model : PN 10 and PN16

Wedge: EPDM EP 83-PW8

Sizes: DN 40

DN 50

DN 60

DN 65

DN 80

DN 100

DN 125

DN 150

DN 200

DN 250

DN 300

DN 350

DN 400

DN 450

DN 500

Series : SÉCULO XXI (straight BSP Female thread – BSP Female thread)

Model : PN 10 en PN16

Wedge: EPDM EP 83-PW8

Sizes : DN 25 (1")

DN 32 (1 ¼")

DN 40 (1 ½")

DN 50 (2")

Series : Series SÉCULO XXI (angle BSP Male thread – BSP Female thread)

Model : PN 10 en PN16

Wedge: EPDM EP 83-PW8

Sizes : DN 25 (1 ¼" – 1")

DN 32 (2" – 1 ¼")

DN 40 (2" – 1 ½")

DN 50 (2" – 2")

The specified products were not assessed for compliance with all ATA aspects as inserted in the "Drinkwaterbesluit" and outlined in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening (implemented 19 July 2011)".

As specified in the mentioned regulations a transition period until July 1st 2013 applies. Before this date the products shall be tested in accordance with clause (article no. 4.2.1) of the Kiwa guideline BRL-K602/04: Valves and other fittings for drinking water transport and distribution systems.

Gate valves

Application and use

Butterfly valves and/or gate valves are designed to, both underground as above ground, be used in pipes for drinking water or raw material for drinking water, with a maximum medium temperature of 30 °C. The valves are designed to open or shut off the pipes and not for regulation purposes.

Marking

The Kiwa[®]-mark products are marked with the word mark "KIWA".

Place of the mark: on the body or specification plate.

Compulsory specifications:

- name or mark of manufacturer: on the body or specification plate;
- identification of the shell material(s): on the body or specification plate;
- nominal size "DN ...": on the body or specification plate;
- nominal working pressure "PN ...": on the body or specification plate;
- identification of the year of manufacture: on the body or specification plate;
- number of the relevant part of the EN1074: on the body or specification plate.

Method of marking:

- Non-erasable;
- visible after assembly.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Fucoli - Somopal fundição de ferro, S.A.

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.